Developing Scalable Applications using Portable Extensible Toolkit for Scientific Computation (PETSc) for the Next-Generation Power Grid

Shrirang Abhyankar

Mathematics and Computer Science Division Argonne National Laboratory

November 15, 2011

- 1 Power system computational challenges
- 2 Introduction to PETSc
- 3 Application Areas
- 4 PETSc Design
- **5** PETSc libraries
- 6 Programming aids
 Debugging
 Profiling
- What's new
- 8 List of power system applications that can be developed using PETSc
- PS applications developed using PETSc
 Real-time electrical power system dynamics
 Combined electromechanical-electromagnetic transients simulation

- 1 Power system computational challenges
- 2 Introduction to PETSc
- 3 Application Areas
- 4 PETSc Design
- 6 PETSc libraries
- 6 Programming aids
 Debugging
 Profiling
- What's new
- 8 List of power system applications that can be developed using PETSc
- 9 PS applications developed using PETSc

Real-time electrical power system dynamics

Combined electromechanical-electromagnetic transients simulation

3 / 49

Next-Generation Power Grid

- Next-generation power grid
 - PMUs, smart meters, Distributed Generation, Plug-in hybrid vehicles, Smart and Micro-grids, Power electronics, Increased communication
- Computational challenges
 - Data explosion , Real-time simulation requirements , Larger or denser network , Multi-scale (temporal, geographical)

Can we develop applications for large systems that run in real-time and capture behavior at a sub-cycle level?

Next-Generation Power Grid


- Next-generation power grid
 - PMUs, smart meters, Distributed Generation, Plug-in hybrid vehicles,
 Smart and Micro-grids, Power electronics, Increased communication
- Computational challenges
 - Data explosion, Real-time simulation requirements, Larger or denser network, Multi-scale (temporal, geographical)

Can we develop applications for large systems that run in real-time and capture behavior at a sub-cycle level?

Next-Generation Power Grid

- Next-generation power grid
 - PMUs, smart meters, Distributed Generation, Plug-in hybrid vehicles,
 Smart and Micro-grids, Power electronics, Increased communication
- Computational challenges
 - Data explosion, Real-time simulation requirements, Larger or denser network, Multi-scale (temporal, geographical)


Can we develop applications for large systems that run in real-time and capture behavior at a sub-cycle level?



One possible solution: Parallel computing

Need to develop parallel scientific computational tool (solver) for specific application (physics) not so easy!!

- Reduce the computational time
- Rapid development of parallel applications
- Reduce the experimentation time and effort




One possible solution: Parallel computing

Need to develop parallel scientific computational tool (solver) for specific application (physics) not so easy!!


- Reduce the computational time
- Rapid development of parallel applications
- Reduce the experimentation time and effort





One possible solution: Parallel computing Need to develop parallel scientific computational tool (solver) for specific application (physics) not so easy!!

- Reduce the computational time
- Rapid development of parallel applications
- Reduce the experimentation time and effort



One possible solution: Parallel computing

Need to develop parallel scientific computational tool (solver) for specific application (physics) not so easy!!

- Reduce the computational time
- Rapid development of parallel applications
- Reduce the experimentation time and effort

- 1 Power system computational challenges
- Introduction to PETSc.
- Application Areas
- 4 PETSc Design
- 6 Programming aids
- What's new
- 8 List of power system applications that can be developed using PETSc

What is PETSc?

Portable Extensible Toolkit for Scientific Computation

- High performance library for the scalable (parallel) solution of scientific applications
- Developed at Argonne National Laboratory
- Mostly used by researchers in PDE applications
- Free for anyone to use, including industrial users
- Download from http://www.mcs.anl.gov/petsc
- Funding
 - Department of Energy
 - National Science Foundation



History of PETSc

Begun in September 1991 as a platform for experimentation



- More than 60,000 downloads since 1995 (version 2)
- About 400 downloads per month
- Awards
 - Top 100 R & D award in 2009
 - Cited as the Top 10 computational science accomplishments of DOE in 2008



Portable Extensible Toolkit for Scientific computing

- Architecture
 - tightly coupled (e.g. Cray XT5, BG/P, Earth Simulator)
 - loosely coupled (network of workstations)
 - GPU clusters (many vector and sparse matrix kernels)
- Operating systems (Linux, Unix, Mac, Windows)
- Any compiler
- Real/complex, single/double/quad precision, 32/64-bit int
- Usable from C, C++, Fortran 77/90, Python, and MATLAB
- Free to everyone, open development, including industrial users

Portable Extensible Toolkit for Scientific computing

Interface for other HP libraries

- BLAS, LAPACK, BLACS, ScaLAPACK, PLAPACK
- MPICH, MPE, Open MPI
- ParMetis, Chaco, Jostle, Party, Scotch, Zoltan
- MUMPS, Spooles, SuperLU, SuperLU_Dist, UMFPack, pARMS
- PaStiX, BLOPEX, FFTW, SPRNG
- Prometheus, HYPRE, ML, SPAI
- Sundials
- HDF5, Boost

Packages can be directly downloaded and installed at configure time --download-<packagename>=1



Who uses PETSc?

- Computational Scientists
 - PyLith (CIG), Underworld (Monash), Magma Dynamics (LDEO, Columbia), PFLOTRAN (DOE), SHARP/UNIC (DOE)
- Algorithm Developers (iterative methods and preconditioning)
- Package Developers
 - SLEPc, TAO, Deal.II, Libmesh, FEniCS, PETSc-FEM, MagPar, OOFEM, FreeCFD, OpenFVM
- Hardware and software vendors
 - Cray and SiCortex
 - Fluent, Tech-X, Actel

What can we handle?

- PETSc has run implicit problems with 1 billion unknowns
 - PFLOTRAN for flow in porous media
- PETSc has run on over 224, 000 cores efficiently
 - UNIC on the IBM BG/P at ANL
 - PFLOTRAN on the Cray XT5 Jaguar at ORNL
- PETSc applications have run at 3 Teraflops
 - LANL PFLOTRAN code


- 1 Power system computational challenges
- 3 Application Areas
- 4 PETSc Design
- 6 Programming aids
- What's new
- List of power system applications that can be developed using PETSc.

Applications of PETSc

- Nano-simulations
- BiologyMedical
- Cardiology
- Imaging and Surgery
- Fusion
- Geosciences
- Environmental/Subsurface Flow
- Computational Fluid Dynamics
- Wave propagation and the Helmholz equation
- Optimization
- Fast Algorithms
- Software engineering
- Algorithm analysis and design
- Electrical Power Systems



Real-time laser surgery



Estimating uranium concentration




Figure: Isopleths of uranium calculated using PFLOTRAN at the Hanford 300 Area





Figure: PFLOTRAN scaling for 2B degrees of freedom

- 1 Power system computational challenges
- Application Areas
- 4 PETSc Design
- 6 Programming aids
- What's new
- List of power system applications that can be developed using PETSc.

Design principles


- Linear algebra interface (Vectors, Matrices, Index sets)
- Distributed, shared nothing
 - User orchestrates communication through higher level interface
 - You almost never will have to use MPI directly
- Object-oriented design
 - Design based on the operations you perform
 - Example : A vector is
 - not a 1-d array but
 - an object allowing addition and scalar multiplication
- Polymorphism
 - User does not need to know the underlying implementation
- Allow solver composition to be set at run-time
 - Great for experimentation
 ./ex -snes_type <ls,tr,test> -ksp_type
 <gmres,cg,bicg,preonly> -pc_type <lu,ilu,icc,jacobi>
 -mat_type <aij,baij,sbaij>

Flow control of a PETSc application



- 1 Power system computational challenges
- Application Areas
- 4 PETSc Design
- **6** PETSc libraries
- **6** Programming aids
- What's new
- List of power system applications that can be developed using PETSc.

Library Organization



Numerical Components

Parallel Numerical Components of PETSc

| Nonlinear Solvers | | | |
|-------------------|--------------|-------|--|
| Newton-ba | sed Methods | Other | |
| Line Search | Trust Region | Otner | |

| Time Steppers | | | | |
|---------------|-------------------|-------------------------|-------|--|
| Euler | Backward Euler | Pseudo-Time Stepping | Other | |

| | | | Krylov Subspace Methods | | | | |
|-------|----|-----|-------------------------|-------|------------|-----------|-------|
| GMRES | CG | CGS | Bi-CG-Stab | TFQMR | Richardson | Chebychev | Other |

| Preconditioners | | | | | | |
|---------------------|-----------------|--------|-----|-----|-------------------------|-------|
| Additive Schwarz | Block Jacobi | Jacobi | ILU | ICC | LU (sequential only) | Other |

| | Matrices | | | | |
|-----------------------------------|--|------------------------------|-------|-------|--|
| Compressed Sparse Row (AIJ) | Block Compressed Sparse Row (BAIJ) | Block Diagonal (BDiag) | Dense | Other | |



| Index Sets | | | | |
|------------|---------|---------------|--------|-------|
| | Indices | Block Indices | Stride | Other |

- 1 Power system computational challenges
- Application Areas
- 4 PETSc Design
- 6 Programming aids Debugging Profiling
- What's new
- 8 List of power system applications that can be developed using PETSc

Debugging

- Automatic generation of tracebacks
- Detection of memory corruption and leaks
- Optional user-defined error handlers
- Launch the debugger
 - -start_in_debugger [gdb, dbx, noxterm]
 - -on_error_attach_debugger [gdb, dbx, noxterm]
- Attach the debugger only to some parallel processes
 - -debugger_nodes 0, 1
- Use valgrind
 - http://www.valgrind.org
 - Checks memory access, cache performance, memory usage, etc.
- Check correctness of analytical Jacobian
 - -snes_type test -snes_test_display



Profiling

- -log_summary
 - Prints a report at the end of the run
 - Reports time, calls, Flops for function calls (called Events)
 - Memory usage for Objects
 - Can set stages for code profiling

Sample -log_summary

```
Time (sec) Flops/sec --- Global --- --- Stage --- Total
Event
               Count
                Max Ratio Max Ratio Mess Avg len Reduct %T %F %M %L %R %T %F %M %L %R Mflop/s
--- Event Stage 0: Main Stage
PetscBarrier
                  2 1.0 1.1733e-05 1.0 0.00e+00 0.0 0.0e+00 0.0e+00 0.0e+00 0 0 0 0 0 0 0 0 0 0
--- Event Stage 1: SetUp
                   2 1.0 9.3448e-04 1.0 0.00e+00 0.0 0.0e+00 0.0e+00 0.0e+00 0 0
VecSet.
                  1 1.0 1.8022e-03 1.0 1.85e+08 1.0 0.0e+00 0.0e+00 0.0e+00 0 0 0 0 0 57 0
MatMultTranspose
                                                                                           0 0 185
MatAssemblyBegin
                  3 1 0 1 0057e-05 1 0 0 00e+00 0 0 0 0e+00 0 0e+00 0 0e+00 0 0
MatAssemblyEnd
                   3 1.0 2.0356e-02 1.0 0.00e+00 0.0 0.0e+00 0.0e+00 0.0e+00 0
Mat.FDColorCreate
                   2 1.0 1.5341e-01 1.0 0.00e+00 0.0 0.0e+00 0.0e+00 4.6e+01 1 0 0 0 16 36 0 0 0 74
--- Event Stage 2: Solve
                  2 1.0 3.2985e-03 1.0 9.56e+07 1.0 0.0e+00 0.0e+00 2.0e+00 0 0
VecDot.
            45 1.0 9.3093e-02 1.0 1.59e+08 1.0 0.0e+00 0.0e+00 1.5e+01 0 0 0 5
VecMDot
VecNorm
                 112 1.0 2.0851e-01 1.0 8.47e+07 1.0 0.0e+00 0.0e+00 5.2e+01 1 1 0 0 18
```

- 1 Power system computational challenges
- Application Areas
- 4 PETSc Design
- 6 Programming aids
- What's new
- 8 List of power system applications that can be developed using PETSc

Splitting for Multiphysics

$$\begin{bmatrix} A & B \\ C & D \end{bmatrix} \begin{bmatrix} x \\ y \end{bmatrix} = \begin{bmatrix} f \\ g \end{bmatrix}$$

Relaxation: -pc_fieldsplit_type
 [additive,multiplicative,symmetric_multiplicative]

$$\begin{bmatrix} A & \\ & D \end{bmatrix}^{-1} \qquad \begin{bmatrix} A & \\ C & D \end{bmatrix}^{-1} \qquad \begin{bmatrix} A & \\ & \mathbf{1} \end{bmatrix}^{-1} \left(\mathbf{1} - \begin{bmatrix} A & B \\ & \mathbf{1} \end{bmatrix} \begin{bmatrix} A & \\ C & D \end{bmatrix}^{-1} \right)$$

- Gauss-Seidel inspired, works when fields are loosely coupled
- Factorization: -pc_fieldsplit_type schur

$$\begin{bmatrix} A & B \\ S \end{bmatrix}^{-1} \begin{bmatrix} 1 \\ CA^{-1} & 1 \end{bmatrix}^{-1}, \qquad S = D - CA^{-1}B$$



Python bindings and MATLAB interface

- Python bindings (petsc4py)
 - Implemented with Cython
 - Easier to write code, maintain, and extend
 - Supports all PETSc libraries
 - http://code.google.com/p/petsc4py
- PETSc-MATLAB interface
 - PETSc functions can be called via MATLAB code.
 - Supports almost all PETSc functionalities
 - Uses 1-based indexing (consistent with MATLAB)

Memory-efficient LU factorization

- Revise LU data structure according to the elements accessed during triangular solves
- Store L forward followed by U backwards
- Provides better Cache performance

Typical LU data structure

$$[L(1,:), U(1,:), L(2,:), U(2,:), ..., L(n,:), U(n,:)]$$


Revised LU data structure

$$[L(1,:), L(2,:), ..., L(n,:), U(n,:), ..., U(2,:), U(1,:)]$$



Support for new architectures

- Graphical Processing Units (GPU)
 - PETSc-3.2 (current version) supports computations on the NViDia GPUs
 - Uses CUSP and Thrust libraries provided by NViDia guys
 - Vec and Mat classes implemented on the GPU
 - Krylov solvers come for free
- Hybrid MPI-shared memory architectures
 - Shared-memory implementation of Vec and Mat using POSIX pthreads





November 15, 2011

Variational Inequalities

$$f(x) = 0$$
s.t. $xl \le x \le xu$

- Supports inequality and box constraints on solution variables.
- Solution methods
 - Semismooth Newton
 - reformulate problem as a non-smooth system, Newton on sub-differential
 - Newton step solves diagonally perturbed systems
 - Active set
 - solve in reduced space by eliminating constrained variables
 - · or enforce constraints by Lagrange multipliers
 - sometimes slower convergence or "bouncing"



Outline

- 1 Power system computational challenges
- Application Areas
- 4 PETSc Design
- 6 Programming aids
- What's new
- 8 List of power system applications that can be developed using PETSc

Power system applications

- Linear (KSP library)
 - DC Power Flow, Sensitivity factors
- Nonlinear (SNES library)
 - AC Power Flow, Contingency analysis, Continuation power flow
 - Distribution power flow, Combined Transmission-distribution power flow
- Time-stepping (TS library)
 - Transient stability, Electromagnetic transients
 - Combined transient stabilty-electromagnetic transients (hybrid simulation)
- Optimization (using TAO)
 - SCOPF
- Eigen-value analysis (using SLEPc)
 - Small signal stability analysis



Outline

- 1 Power system computational challenges
- Application Areas
- 4 PETSc Design
- **6** Programming aids
- What's new
- 8 List of power system applications that can be developed using PETSc
- 9 PS applications developed using PETSc Real-time electrical power system dynamics Combined electromechanical-electromagnetic transients simulation

Transient Stability Simulators (TS)

- For studying relatively slow dynamic behavior (generator dynamics)
- Assumptions
 - Constant frequency (phasor representation of voltages/currents)
 - Can use larger time step (in the order of milliseconds)
 - Allow analysis of large-scale systems.
 - Balanced transmission network (positive sequence network)
- Limitations of balanced transmission network
 - Unbalanced operation or systems
 - Single phase switching operations
 - Only positive sequence information available

Three phase dynamics simulator (TS3ph)

- Full three-phase coupled network model of the transmission network.
- Still uses constant frequency assumption as in TS.
- Can additionally
 - Simulate unbalanced operation
 - Single phase switching operations
 - Provide information on dynamics of all three phases
 - Model individual load dynamics on different phases
 - Can be also used for distribution systems

Problem formulation

Nonlinear differential-algebraic three-phase power system model

$$\begin{split} \frac{dx_{gen}}{dt} &= f(x_{gen}, I_{dq}, V_{DQ,abc}) \\ &0 = h(x_{gen}, I_{dq}, V_{DQ,abc}) \\ \begin{bmatrix} G_{3ph} & -B_{3ph} \\ B_{3ph} & G_{3ph} \end{bmatrix} \begin{bmatrix} V_{D,abc} \\ V_{Q,abc} \end{bmatrix} = \begin{bmatrix} I_{genD,abc}(x_{gen}, I_{dq}) \\ I_{genQ,abc}(x_{gen}, I_{dq}) \end{bmatrix} - \begin{bmatrix} I_{loadD,abc}(x_{load}, V_{DQ,abc}) \\ I_{loadQ,abc}(x_{load}, V_{DQ,abc}) \end{bmatrix} \\ \frac{dx_{load}}{dt} &= f_2(x_{load}, V_{DQ,abc}) \end{split}$$

Equations to solve at each time step

$$x(t+\Delta t) - x(t) - \frac{\Delta t}{2} \left(f(x(t+\Delta t), y(t+\Delta t)) + f(x(t), y(t)) \right) = 0$$
$$g(x(t+\Delta t), y(t+\Delta t)) = 0$$

Variables


$$x \equiv [x_{gen}, x_{load}]^{t}$$
$$y \equiv [I_d, I_q, V_{D,abc}, V_{Q,abc}]^{t}$$


Shrirang Abhyankar (ANL)

PETSc

November 15, 2011 38 / 49

TS3ph benchmarking with PSS/E on WECC 9-bus system







Shrirang Abhyankar (ANL)

Unbalanced faults


Positive-sequence voltages




Three-phase voltages



Parallel performance of TS3ph






*Scalabilty results of 1180 bus, 2035 branches, 540 generator


- Parallel linear solves too expensive!!
- Results of experiments to speed up linear solves
 - Preconditioner Iterative solver GMRES more scalable than parallel direct solver (MUMPS)
 - Parallel Block-Jacobi (Block-Diagonal) preconditioning
 - Very dishonest preconditioning strategy (Pai et. al.)

4 D > 4 D > 4 E > 4 E > E 9 Q Q

system

Parallel performance of TS3ph





 Scalabilty results of 2360 bus, 4670 branches, 1080 generator system

Power system dynamic analysis methods

- Electromechanical dynamics simulation
 - Assess "slow" generator dynamics
 - Time step in the order of milliseconds
 - Phasor modeling
 - Can be used for large-scale system analysis.
- Electromagnetic transients simulation
 - Analyze "faster" dynamics such as that of power electronics
 - Time step in the order of microseconds
 - No constant frequency assumption
 - Inefficient for large-scale system analysis
- Combined electromechanical-electromagnetic transients simulator ("hybrid" simulator)
 - Capture "global" slow dynamics and "local" fast dynamics
 - Use TS globally and EMT locally
 - Need interface for
 - Time step
 - Network modeling
 - Waveform



Power system dynamic analysis methods

- Electromechanical dynamics simulation
 - Assess "slow" generator dynamics
 - Time step in the order of milliseconds
 - Phasor modeling
 - Can be used for large-scale system analysis.
- Electromagnetic transients simulation
 - Analyze "faster" dynamics such as that of power electronics
 - Time step in the order of microseconds
 - No constant frequency assumption
 - Inefficient for large-scale system analysis
- Combined electromechanical-electromagnetic transients simulator ("hybrid" simulator)
 - Capture "global" slow dynamics and "local" fast dynamics
 - Use TS globally and EMT locally
 - Need interface for
 - Time step
 - Network modeling
 - Waveform




Power system dynamic analysis methods

- Electromechanical dynamics simulation
 - Assess "slow" generator dynamics
 - Time step in the order of milliseconds
 - Phasor modeling
 - Can be used for large-scale system analysis.
- Electromagnetic transients simulation
 - Analyze "faster" dynamics such as that of power electronics
 - Time step in the order of microseconds
 - No constant frequency assumption
 - Inefficient for large-scale system analysis
- Combined electromechanical-electromagnetic transients simulator ("hybrid" simulator)
 - Capture "global" slow dynamics and "local" fast dynamics
 - Use TS globally and EMT locally
 - Need interface for
 - Time step
 - Network modeling
 - Waveform



Existing "explicit" hybrid simulation approach




- Make separate TS and EMT programs talk to each other
- Explicit approach
- No iterations between TS and EMT
- Diverges for large changes in voltages/currents

□ ト 4 個 ト 4 種 ト 4 種 ト ■ 9 Q (*)

Proposed "implicitly-coupled" hybrid simulation approach

- Combine TS and EMT at the equation level rather than at the application level
- Solve TS equations and coupled-in-time EMT equations for each TS time step together
- More robust than the explicit approach
- Allows a parallel implementation
- Proposed multi-scale dynamics simulation strategy
 - Only run hybrid simulator when needed, run TS for all other times



| Value | Val


Combined electromechanical-electromagnetic transients simulation

Time-comparison of different dynamic analyses

| System size | Simulated time (sec) | TS3ph | EMT | Only TSEMT | TS3ph-TSEMT |
|-------------|----------------------|-------|------|------------|-------------|
| 9 bus | 3 | 0.13 | 4.96 | 5.46 | 0.41 |
| 118 bus | 3 | 0.36 | 30.1 | 4.87 | 0.53 |

Parallel implementation and performance results

- Partition TS network in space and EMT network in time
- Each processor gets equations for
 - TS subnetwork
 - EMT equations for multiple time-steps



*2360 buses total, 4 buses,3 transmission lines and 4 loads in EMT network

- 4 ロ ト 4 周 ト 4 ヨ ト - ヨ - り Q (^)

^{*}Using GMRES + Very Dishonest preconditioning

PETSc use in the example applications

- Easy parallel implementation
- Partitioning (using ParMetis)
- Linear solver (using KSP and PC libraries)
- Nonlinear solver (SNES library)
- Portable code
- Reduced experimentation time
 - Set different algorithms at run-time!!

The Role of PETSc

Developing parallel, nontrivial applications that deliver high performance is still difficult and requires months (or even years) of concentrated effort.

PETSc is a toolkit that can ease these difficulties and reduce the development time, but it is not a black-box solver, nor a silver bullet.

— Barry Smith